## **Declaration of Performance**



## DoP Number:

1 Unique identification code of the product-type:

2 Identification of the construction product as required under Article 11(4) of the regulation n° 305/2011/EU:

MW-EN 14303-T4-ST(+)650-WS1-MV1-CL10-F10-pH10,5

FIBRANgeo TB-080-AL

3 Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Thermal insulation for building equipment and industrial installations

4 Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5) of the regulation n° 305/2011/EU:

FIBRAN S.A. 56010, Thessaloniki, Greece

5 Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2) of the regulation n° 305/2011/EU:

Not applicable

GR-3038-001

6 System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V of the Regulation n° 305/2011/EU:

AVCP - System 1

7 Notified Certification bodies FIW (Forschunginstitut für Wärmeschutz e.v München) N° 0751 and MPA (Materialprüfanstalt fün das Bauwesen Hannover) N° 0764 performed, carried out the determination of the product type, the initial inspection of the manufacturing plant and of factory production control and the continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance for reaction to fire.

0751-CPD.2-001.0-01

## ${\bf 8}\ \ {\bf Declared}\ {\bf performance} {\bf according}\ {\bf to}\ {\bf harmonized}\ {\bf standard:}$

EN 14303:2009 + A1:2013

Essential characteristics	Performance	Abreviation	Unit	Declared performance		
Reaction to fire	Reaction to fire	RtF	Euroclass	A1		
Acoustic absorption index	Acoustic absorption index			1		
	Thermal Conductivity	λ <sub>D</sub>	W/m K	See table below		
Thermal Resistance	Thickness	d <sub>N</sub>	mm	30-160		
Thermal nesistance	Thickness Tolerance	т	Class	T4		
Water Permeability	Water Absorption	WS	kg/m²	1		
Water vapour permeability	Water Vapour diffusion equivalent air layer MV thickness			1		
Compressive strength	Compression stress at 10% deformation	CS	kPa	1		
	Trace of quantities of water-soluble chloride	CL	ppm	10		
Rate of release of corrosive substances	ions and pH-value	F	ppm	10		
	ions and private	pH		10,5		
Realease of Dangerous Substances	Realease of Dangerous Substances			NPD		
Realease of Dangerous Substances	Continuous Glowing Combustion			NPD		
Durability of reaction to fire against ageing/degradation	Durability of reaction to fire against ageing/degradation			According to EN 14303		
Durability of thermal resistance against ageing/degradation	Durability of thermal resistance against ageing/degradation			According to EN 14303		
Durability of reaction to fire against high temperature	Durability of reaction to fire against high temperature			According to EN 14303		
Duranbility of thermal resistance against high temperature	Maximum Service Temperature	ST	℃	650		
NPD: No Performance Determined		1	ı	1		

9 The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

Temperature	10	50	100	150	200	250	300	350	400	500	600	650
λ W/mK	0,033	0,040	0,046	0,053	0,061	0,072	0,080	0,095	0,105	0,136	0,172	0,195

 $This \ declaration \ of \ performance \ is \ is sued \ under \ the \ sole \ responsibility \ of \ the \ manufacturer \ identified \ in \ point \ 4.$ 

Name: Dr. Chadiarakou Stella
Function: Quality Assurance Manager

Place: Thessaloniki
Date: 19/3/2021
Signature: